

RFI Clarifications

Please see clarification for note #8 and note #6 for Flagpoles

8. In the warehouse that is to remain, there are two existing rollup doors. Are these to be protected in place or replace? If replaced, please provide specifications.
 - a. WSCS Walls , slab, footings, doors, roof, and demising wall all to be removed an demolished in west site of the building per demo plan east side of building to be protected

6. On sheet 2 of 3 for the civils, calls for three (3) flag poles. Are these by the Owner or GC? If by GC, can you please provide specifications for poles and footings?
 - a. WSCS Owner has installed the corrugated pipe in the ground for the flag poles. The flag poles will need to be installed by the contractor and filled with silica sand.