

- FRESH AIR INTAKES SHALL BE 10'-0" MIN. AWAY FROM ALL EXHAUST OUTLETS, PLUMBING VENTS, AND FLUES.
- CONTRACTOR SHALL PROVIDE SHOP DRAWINGS WITHIN 45 DAYS OF AWARD OF CONTRACT. SEE SPECIFICATIONS FOR REQUIREMENTS. IF SHOP DRAWINGS ARE NOT PROVIDED TO THE ENGINEER FOR APPROVAL, AND ANY CONFLICTS OCCUR BETWEEN TRADES, DURING CONSTRUCTION, & ETC., THEN, THE CONTRACTOR SHALL BE RESPONSIBLE AND BEAR ALL COST INCURRED FOR ANY REVISIONS. AT NO ADDITIONAL COST TO THE DISTRICT. THE DISTRICT AND ENGINEER SHALL BE NOTIFIED IMMEDIATELY PRIOR TO FABRICATION AND INSTALLATION OF ANY CONFLICTS BETWEEN TRADES, DURING CONSTRUCTION, & ETC.
- VERIFY PAINT COLOR OF ALL EXPOSED DUCTWORK AND AIR DISTRIBUTION EQUIPMENT WITH ARCHITECT.
- CONTRACTOR SHALL IDENTIFY ALL HVAC EQUIPMENT WITH STORE NAME AND UNIT NUMBER USING PERMANENT, WEATHER PROOF 2" HIGH DIE-CUT LETTERS.
- ANY PENETRATION THROUGH THE ROOF SHALL BE COORPINATED WITH THE LANDLORD'S FIELD REPRESENTATIVE AND SHALL BE DONE BY A LANDLORD APPROVED ROOFING CONTRACTOR IN ORDER TO MAINTAIN THE ROOFING WARRANTY. ALL VENTS SHALL EXTEND A MINIMUM OF 12 INCHES ABOVE ROOF AND SHALL BE A MINIMUM OF 10 FEET FROM ANY OUTSIDE AIR INTAKE.
- ALL DUCT SIZES SHOWN ARE CLEAR INSIDE AIR FLOW DIMENSIONS.
- AIR EXTRACTORS OR SPLITTER DAMPERS SHALL NOT PROTRUDE INTO RECTANGULAR TRUNK DUCTS. PROVIDE ROUND SPIN-IN FITTINGS FOR ROUND BRANCH DUCTS.
- ROUND BRANCH DUCTS WHERE INDICATED ARE SAME SIZE AS ATTACHED DIFFUSER NECK SIZE.
- DO NOT SUSPEND ANY ITEMS FROM DECK OR SLAB ABOVE. ALL ITEMS SHALL SUSPENDED FROM STRUCTURE UNLESS OTHERWISE NOTED. PROVIDE MISCELLANEOUS STEEL AS REQUIRED.
- WHERE CEILING SPACE IS NOT SUFFICIENT TO PERMIT TOP CONNECTION TO CEILING DIFFUSER WITH PROPER BEND RADIUS FOR FLEXIBLE DUCT, CONTRACTOR SHALL FABRICATE AND/OR PROVIDE AN ADAPTER BOX FOR DIFFUSER TO PERMIT SIDE CONNECTION OF FLEXIBLE DUCT.
- CONTRACTOR SHALL COORDINATE AND SCHEDULE ALL WORK WITH LANDLORD'S FIELD REPRESENTATIVE.
- PROVIDE SUPPORT FOR PIPING ON ROOF PER LANDLORDS ROOFING CONTRACTORS RECOMMENDATIONS.
- PROVIDE MANUAL DAMPER FOR AIR BALANCE AT ALL BRANCH TAKE-OFFS. DAMPER TO BE THE SAME SIZE AS THE BRANCH TAKE-OFF.

GENERAL NOTES


CLTO MOUNTED W/5#
EX. DUCT UTR TO ROOF
VENT W/ BRD & BRD
SCREEN, UNDER CUT
DOOR MIN. 1", TYP.

PROVIDE VOLUME DAMPER AT ALL
BRANCH TAKE OFFS FOR BALANCING
FOOTPRINT MODEL CD-10R, TYP. ALL

ON ROOF CURB WITH 18" S&R
SET OSA PER 724 REPORT W/
BACKDRIFT DAMPER & BRD
SCREEN, TYP. HP-14&2.

ON ROOF CURB WITH 14" S&R
SET OSA PER 724 REPORT W/
BACKDRIFT DAMPER & BRD
SCREEN, TYP. HP-3,5&6.

ON ROOF CURB WITH 16" S&R
SET OSA PER 724 REPORT W/
BACKDRIFT DAMPER & BRD
SCREEN, TYP. HP-4&7.



5.410.2 commissioning for newbuildings 10,000 square feet and over, building commissioning shall be included in the design and construction processes of the building project to verify that the building systems and components meet the owner's or other representative's project requirements. Commissioning shall be performed in accordance with this section by trained personnel with experience on projects of comparable size and complexity.

5.410.2.1 Owner's or other representative's Project Requirements (OPR). The expectations and requirements of the building appropriate to its phase shall be documented before the design phase of the project begins.

5.410.2.2 Basis of Design (BOD). A written explanation of how the design of the building systems meets the OPR shall be completed at the design phase of the building project, and updated as necessary during the design and construction phases. The Basis of Design document shall cover the following:

5.410.2.3 Commissioning plan. Prior to permit issuance a commissioning plan shall be completed to document how the project will be commissioned and shall be started during the design phase of the building project. The Commissioning Plan shall include the following:

5.410.2.4 Functional performance testing. Functional performance tests shall demonstrate the correct installation and operation of each component, system and system-to-system interface in accordance with the approved plans and specifications. Functional performance testing reports shall contain information addressing each of the building components tested, the testing methods utilized, and include any readings and adjustments made.

5.410.2.5.1 Systems manual. Documentation of the operational aspects of the building shall be completed within the Systems Manual and delivered to the building owner or representative and facilities operator. The Systems Manual shall include the following:

5.410.2.5.2 Systems operations training. The training of the appropriate maintenance staff for each equipment type and/or system shall be documented in the commissioning report and shall include the following:

5.410.2.6 Commissioning report. A complete report of commissioning process activities undertaken through the design, construction and reporting recommendations for postconstruction phases of the building project shall be completed and provided to the owner or representative.

5.410.4 Testing and adjusting. Testing and adjusting of systems shall be required for buildings less than 10,000 square feet.

5.410.4.2 Systems. Develop a written plan of procedures for testing and adjusting systems. Systems to be included for testing and adjusting shall include at a minimum, as applicable to the project:

5.410.4.3 Procedures. Perform testing and adjusting procedures in accordance with industry best practices and applicable standards on each system as determined by the building official.

5.410.4.3.1 HVAC balancing. In addition to testing and adjusting, before a new space-conditioning system serving a building or space is operated for normal use, the system shall be balanced in accordance with the procedures defined by the Testing Adjusting and Balancing Bureau National Standards, the National Environmental Balancing Bureau Procedural Standards, or Associated Air Balance Council National Standards or as approved by the building official.

5.410.4.4 Reporting. After completion of testing, adjusting and balancing, provide a final report of testing signed by the individual responsible for performing these services.

5.410.4.5 Operation and maintenance (O&M) manual. Provide the building owner or representative with detailed operating and maintenance instructions and copies of warranties/ warranties for each system.

5.508.1.1 Chlorofluorocarbons (CFCs). Install HVAC, refrigeration and fire suppression equipment that do not contain CFCs.

5.508.1.2 Halons. Install HVAC, refrigeration and fire suppression equipment that do not contain Halons.



GEORGE BEHNAME, AIA
ARCHITECT
1150 E. ORANGETHORPE # 109
PLACENTIA, CA 92870
(714)572-2384 FAX(714)572-2385
E-mail: GBehnam@abcplbca.net

SMA
MECHANICAL ENGINEER
524 TOPSIDE PLACE
DIAMOND BAR, CA 91765
(909)860-9844 FAX(425)860-7567

PROJECT:
FOOTHILL RANCHO PLAZA
9606 FOOTHILL BLVD
RANCHO CUCAMONGA, CA

DEVELOPER:
CALIFORNIA LIBERTY INVESTMENTS
537 CERES AVE
LOS ANGELES, CA 90013

PROJECT NO. 120102
CADDWG FILE:
DRAWN BY: M.M.
CHECKED BY: G.B.
SCALE: NOTED
DATE: 04-08-12
SHEET TITLE:
BLDG. A & B
HVAC
SHEET M-2.1
2 OF 7

REVISIONS	DATE	DESCRIPTION

DEVELOPER:
CALIFORNIA LIBERTY INVESTMENTS
 537 CERES AVE
 LOS ANGELES, CA 90013

PROJECT:
FOOTHILL RANCHO PLAZA
 9606 FOOTHILL BLVD
 RANCHO CUCAMONGA, CA


SMA
 MECHANICAL ENGINEER
 524 TOPSIDE PLACE
 DIAMOND BAR, CA 91765
 (909)860-9844 FAX(425)660-7567

GEORGE BEHNAME, AIA
 ARCHITECT
 1150 E. ORANGETHORPE # 109
 PLACENTIA, CA 92870
 (714)572-2384 FAX(714)572-2385
 E-mail: GBehnam@abcglobal.net

PROJECT NO: 120102
 CAD/DWG FILE:
 DRAWN BY: M.M.
 CHECKED BY: G.B.
 SCALE: NOTED
 DATE: 04-08-12
 SHEET TITLE:
BLDG. C
HVAC
 SHEET
M-2.2
 3 OF 7

MECHANICAL ACCESSORIES

T-848 CEILING SUPPLY (CS) ANEMOSTAT PNE/ROD, TITILE & BAILEY 401R, TYPE3
 T-848 CEILING RETURN (CR) ANEMOSTAT 3RD, TITILE & BAILEY 401R, TYPE3,
 TYPICAL FOR EXHAUST GRILLE (CE) AND TRANSFER GRILLE (TO)
 HARD CEILING SUPPLY (CS) ANEMOSTAT RND-S, TITILE & BAILEY 160L,
 HARD CEILING RETURN (CR) ANEMOSTAT SSXND, TITILE & BAILEY 160L,
 TYPICAL FOR EXHAUST GRILLE (CE) AND TRANSFER GRILLE (TO)
 SIDE WALL SUPPLY (SWS) ANEMOSTAT 520W-08D, TITILE & BAILEY 160L,
 SIDE WALL RETURN (SWR) ANEMOSTAT X30HD-08, TITILE & BAILEY 160L,
 T-848 C/C, 180GZ, THRUW SUPPLY SCOT, AIR MANAGERS & LTR, T-848 OR ANEMOSTAT,
 FLOOR SUPPLY (FS) ANEMOSTAT T15NR, TITILE & BAILEY 440R-08D W/
 STRAIGHTENING VANES, FENCUL, TITILE & BAILEY 420H, W/
 FLOOR RETURN (FR) ANEMOSTAT T15NR, TITILE & BAILEY 420H, W/
 STRAIGHTENING VANES, FENCUL AND SHOE HEEL PROOF.
 SUPPLY & RETURN RESPECTIVELY.
 T-1-08D, ELIMINATE 08D FOR RETURN, FRAME TO MATCH CEILING TYPE.
 MAX. 50 CFM/H/150T SUPPLY & MAX. 50 CFM/H/150T RETURN, BAILEY,
 EXPOSED OVA RETURN OR TRANSFER SHALL ANEMOSTAT 520D OR TITILE & BAILEY,
 FIRE DAMPERS:
 ALL CEILING FIRE DAMPERS SHALL BE POTTORFF, CD-15-ES OR CFB-20-ES.
 ALL CEILING FIRE DAMPERS SHALL BE POTTORFF, WD-100-15B.
 ALL CEILING FIRE DAMPERS SHALL BE POTTORFF, NO. 6057A.
 ALL ACCESS DOORS SHALL BE POTTORFF, NO. 60-440.
 ALL ACCESS DOORS SHALL BE POTTORFF, NO. 6057A.
 ALL SOUND TRAPS SHALL BE DIMENSIONAL CERTIFIED BY VWAP.
 ALL SOUND TRAPS SHALL BE DIMENSIONAL CERTIFIED BY VWAP.
 ALL PERFORMANCE DATA TESTED ACCORDING TO E-477-99



ALL ECONOMIZERS SHALL HAVE MANDATORY FAULT DETECTION DIAGNOSIS CONTROLS AND MODULATING COOLING CAPACITY. UNITS 6,25 TON AND GREATER SHALL HAVE VARIABLE AIR FLOW SUPPLY FANS. NEW PROJECTS MANDATORY REQUIREMENTS FOR AS BUILT COMMISSIONING.

ITEM	MFG. & MODEL	CL'G	HT'G	CFM	ELEC.	MCA	MOCF	WT	REMARKS	DIMENSIONS
HP 2.5ton	CARRIER 50EZ-A30	28,800	29,000	1000	208-230/60/1	25	40	340	13.5/11.5 7.7/3.5	44x37x51 HEIGHT= 37 +14"CURB
HP 3ton	CARRIER 50TCOA04 INTEGRATED ECONOMIZER	35,600	34,800	1200	208-230/60/3	25	30	505	13.4/11.0 7.7	6'x4'x48 UNIT HT= 34 +14"CURB
HP 5ton	CARRIER 50TCOA06 INTEGRATED ECONOMIZER	58,000	55,000	2000	208-230/60/1	44	60	990	13.4/11.0 7.7	6'x4'x48 UNIT HT= 34 +14"CURB
EF 1	ACME VO-150	-	-	124 0.50"	120/60/1ø	1.3	23		CEILING MOUNTED W/ BACKDRAFT DAMPER, INTERLOCK WITH RM LIGHTS	12"X15"X10"

