



DEMO NOTES

- 1 REMOVE SPACE HEATER AND RELATED APPURTENANCES. DISCONNECT AND CAP GAS PIPE ON ROOF. REMOVE FLUE THRU ROOF AND REPAIR ROOF AS NEEDED TO MAINTAIN EXISTING ROOF WARRANTY.
- 2 (E) RELIEF AIR OPENING TO REMAIN.
- 3 (E) EXHAUST FAN ON ROOF AND ALL RELATED DUCTWORK TO BE REMOVED. CURB SHALL BE CAPPED WITH A MINIMUM OF R-30 INSULATION ON UNDERSIDE OF CAP.
- 4 (E) RELIEF AIR OPENING AND HOOD TO BE REMOVED. CURB SHALL BE CAPPED WITH A MINIMUM OF R-30 INSULATION ON UNDERSIDE OF CAP.

THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF WHEELER & WHEELER ARCHITECTS, INC. AND SHALL NOT BE REPRODUCED WITHOUT THE WRITTEN CONSENT OF WHEELER & WHEELER ARCHITECTS, INC. THESE DRAWINGS ARE NOT TO BE USED FOR ANY OTHER WORK, OR PORTION THEREOF, THAN THAT NOTED ON TITLE BLOCK. IF THERE IS A DISCREPANCY BETWEEN THESE DRAWINGS AND ANY OTHER DOCUMENTS, THESE DRAWINGS SHALL PREVAIL. WHEELER & WHEELER ARCHITECTS, INC. 2011 WHEELER & WHEELER ARCHITECTS, INC.

NO.	DATE	REVISION
1	10/28/15	PLAN CHECK SUBMITTAL
2	12/14/15	PLAN CHECK REVISIONS

WHEELER & WHEELER
ARCHITECTURE ■ INTERIORS ■ PLANNING
133 South Spring Street, Claremont, California 91711 909-874-5095 FAX 909-874-6911-7757
WWW.WHEELER-AND-WHEELER.COM ARCHITECTS REGISTERED IN CALIFORNIA

MECHANICAL DEMO FLOOR PLAN
TENANT IMPROVEMENT & EXTERIOR FACADE IMPROVEMENTS FOR:
Get Air
S.E. Quadrant, Pomona 60 FWY at Corona Expressway
Pomona, California 91766

DATE	05.04.15
JOB NO.	AIR-2521
DRAWN BY	SL

DRAWING NO.
M1.0

APN NO. 8331-016-021

DESIGN WEST ENGINEERING
MECHANICAL • ELECTRICAL • ENERGY CONSULTANTS
275 W. Hospitality Lane, Suite #100
San Bernardino, CA 92408
Phone: 909.890.3700
Fax: 909.890.3700
Email: ccs@designwesteng.com